



Power converter for the TT2 mercury target project

by

Carlos DE ALMEIDA MARTINS (AB/PO)




Historic overview



First technical proposal (on 31 March 2004):

ALICE/LHCb type power converter rated 6500Adc, 950Vdc, 6.7 MW









target

First technical proposal (on 31 March 2004):

ALICE/LHCb type power converter rated 6500Adc, 950Vdc, 6.7 MW

Converter location

Possibility # 1 - in the ISR gallery


Short DC cables, between the power converter and the magnet (~30m);

Long AC cables, between the 18kV cell (in bld 193, AD) and the power

converter

Possibility # 2 - in bld 193, AD

- Longer DC cables, between the power converter and the magnet;
- Short AC cables, between the 18kV cell (available in bld 193, AD) and the power converter





Historic overview



First technical proposal (on 31 March 2004):

ALICE/LHCb type power converter rated 6500Adc, 950Vdc, 6.7 MW

Advantages:

- Brand new system;
- Forced air cooling (no need for water circuit)
- Cast resin power transformers. Can be placed indoor

Inconveniences:

- Already short in time for buying a new power converter;
- Already short in time for buying the power transformers;
- One ALICE/LHCb spare power transformer can be lend, but that implies higher current harmonics in the 18 kV distribution network;
- Ultimate current 7250A output;
- Price: ~300 kCHF for the rectifier part only.



Historic overview



Second technical proposal (~November 2004):

Decommissioned West Area (WA) power converter rated 8000Adc, 1000Vdc,
 8 MW

Advantages:

- Availability at the moment;
- Higher current and voltage ratings;
- Available power transformers, allowing low current harmonic distortion on the 18kV network
- Price (detailed later)


Inconveniences:

- Water cooled. Needs water connection to the power converter;
- Oil transformers. Need to be placed outdoor, in a special pit, for security reasons;
- Refurbish of power part and control/interlocks cabling



West Area power converter 8000Adc, 1000Vdc





C. A. Martins, CERN AB/PO




West Area power converter 8000Adc, 1000Vdc



Converter photos, 1

Global view



Rectifier bridges



Passive filter self



Passive filter capacitors





West Area power converter 8000Adc, 1000Vdc



Converter photos, 2

DCCT



CROWBAR & controls



Power transformers





AB/PO proposition 8000Adc, 1000Vdc



Strategy:

• Refurbishment of the West Area Power Converter, making it compatible with the project requirements

Conserving the main components of the power part



Installing a new digital control electronic system, type PS



17.March.2005

C. A. Martins, CERN AB/PO




AB/PO proposition 8000Adc, 1000Vdc



Power Converters location:

• At building 193 (AD) like ALICE/LHCb converter 2nd choice



17.March.2005

C. A. Martins, CERN AB/PO



AB/PO proposition 8000Adc, 1000Vdc




Available infrastructures at building 193 (AD):

- Water circuit in the vicinity of the power converter's location;
- Pit for placement of the power transformer (outside the building);

• 18 kV cell





17.March.2005

C. A. Martins, CERN AB/PO



AB/PO proposition 8000Adc, 1000Vdc



Estimated tasks, at charge of AB/PO, for refurbishment and costs:

 Disassembling of power converter at its actual and transport to its final location (Bld 193,AD); 	l location (BA6) 10 kCHF
Preparation of the zone for reception;	5 kCHF
Reassembling, cabling work;	15 kCHF
• New DCCT;	10 kCHF
New control electronics;	10 kCHF
Connection to the water circuit;	10 kCHF
Test and commissioning	40 kCHF
• Decommissioning	10 kCHF
47.14	Total 110 kCHF



AB/PO proposition 8000Adc, 1000Vdc



Tasks not at charge of AB/PO (at charge of TS/EL)

- AC cabling between the 18kV cell and power transformer;
- AC cabling between power transformer and thyristor rectifier bridges;
- DC cabling between the power converter and the magnet