IDS120hm GEOMETRY WITH MODIFIED Hg POOL VESSEL

SIMULATIONS FOR 60% W + 40% He SHIELDING WITHOUT/WITH Hg IN THE POOL AND REMOVING SH1 (P11/P12 'POINTS')

Nicholas Souchlas, PBL (11/29/2011)

IDS120hm: (m IS FOR) modified Hg pool vessel IN IDS120h. # WITHOUT AND WITH Hg IN THE POOL SIMULATIONS. # REMOVING SH1. # P11/P12 INITIAL PROTON BEAM POSITION SIMULATIONS.


>mars1510/MCNP >10⁻¹¹ MeV NEUTRON ENERGY CUTOFF >SHIELDING: 60% W + 40%H e (WITH W VESSELS)

>4 MW proton beam, Np = 100,000 events.


>PROTON ENERGY E = 8 GeV.

>GAUSSIAN PROFILE: $\sigma_x = \sigma_y = 0.12$ cm.

IDS120hm GEOMETRY = IDS120h WITH MODIFIED Hg POOL VESSEL AND SHIFTED Be WIDOW FROM 600 cm (0.6 cm THICK) TO 300 cm (1 cm THICK).





P11 AND P12 INITIAL PROTONS BEAM POSITION POINTS WILL BE USED FOR THE SIMULATIONS. PROJECTION OF P11 (BLACK) AND P12 (RED) PROTONS TRAJECTORY PLOTS.





P12 PROTONS ENTER THE Hg POOL SOONER AND THEREFORE HAVE A LONGER TRAJECTORY.

IDS120hm WITH Hg IN THE POOL UP TO y = - 15 cm (LEFT) AND UP TO y = - 20 cm (RIGHT)










POOL WITH Hg AT y = - 20 cm HAS SURFACE LEVEL 5 cm BELLOW BEAM PIPE AT z = 300 cm P11: TRAJECTRORY LENGTH ~ 104 cm ~ 7 IL P12: TRAJECTRORY LENGTH ~ 131 cm ~ 9 IL (1 IL~ 15 cm) ** IS THIS ADEQUATE ?? ** WILL BE USED FOR SIMULATIONS WITH Hg IN THE POOL.

IDS120hm WITHOUT SH1, Hg SURFACE IN POOL AT y = - 20 cm (WORK STILL IN PROGRESS)



Aspect Ratio: Y:Z = 1:2.32142

TABLES NOTATION: C1 = IDS120hm WITHOUT Hg IN THE POOL VESSELC2 = IDS120hm WITH Hg IN THE POOL VESSEL, SURFACE AT y = - 20 cmC3 = IDS120hm WITHOUT SH#1, Hg POOL SURFACE AT y = - 20 cmFOR EACH CASE BOTH P11 / P12 INITIAL PROTON BEAM POSITIONS EXAMINED

POWER DEPOSITED IN THE SC COILS

NiSn/NiTi	C1(P11)	C1(P12)	C2(P11)	C2(P12)	C3(P11)	C3(P12)
SC#1	0.237	0.181	0.209	0.160	0.225	0.274
SC#2	0.033	0.037	0.042	0.044	0.034	0.046
SC#3	0.014	0.020	0.042	0.044	0.038	0.053
SC#4	0.026	0.032	0.028	0.026	0.025	0.028
SC#5	0.013	0.023	0.004	0.007	0.005	0.005
SC#6	0.003	0.002	0.001	0.001	0.007	0.007
SC#1-6	0.326	0.295	0.326	0.282	0.334	0.413
SC#7-9	0.054	0.051	0.060	0.050	0.047	0.049
SC#10-12	0.060	0.052	0.070	0.050	0.057	0.053
SC#13-15	0.045	0.037	0.026	0.044	0.041	0.045
SC#16-19	0.075	0.067	0.063	0.070	0.055	0.056
SC#1-19	0.560	0.502	0.545	0.496	0.534	0.617

SC1: 0.160 kW - 0.274 kW SC1-6: 0.282 kW - 0.413 kW SC#1-19: > 0.5 kW

SMALL FLUCTUATIONS BETWEEN P11 AND P12 POINTS.

NO SIGNIFICANT ISSUES IN TERMS OF DP IN SC's.

POWER DEPOSITED IN THE SHIELDING (SH#), SHIELDING VESSELS (SHVS#), AND SH1 W TUBE 2 (SH1T2)

—	C1(P11)	C1(P12)	C2(P11)	C2(P12)	C3(P11)	C3(P12)
SH#1A	556.50	554.50	560.50	560.50	—	_
SH#1B	343.90	385.90	340.70	391.70	442.20	485.75
SH#2	616.50	561.00	244.20	181.45	242.00	189.45
SH#3	24.22	22.36	24.08	22.18	24.27	22.05
SH#4	61.95	65.30	79.15	82.55	103.50	106.00
SH#1-4	1603.07	1589.06	1248.63	1238.38	813.97	803.25

SH#1A: > 0.5 MW FOR C1, C2 SH#1B: P12 - P11 ~ +40.0 kW C1, C2 --> C3 ~ +100.0 kW SH#2 : P12 - P11 > -50.0 kW C1 --> C2, C3 ~ -370.0 kW SH#1-4: P12 - P11 ~ SMALL SO MOSTLY REDISTRIBUTION OF DP IN SH. C1 --> C2 --> C3 ~ -350 kW / -800 kW

_	C1(P11)	C1(P12)	C2(P11)	C2(P12)	C3(P11)	C3(P12)
SHVS#1	54.60	56.20	61.80	49.74	_	_
SHVS#2	101.25	106.15	93.55	92.90	235.15	238.30
SHVS#3	0.88	0.78	0.83	0.77	0.82	0.80
SHVS#4	25.33	26.68	41.23	44.94	54.40	57.45
SHVS#1-4	182.06	189.81	197.41	188.35	290.37	296.55
SH1T2(W)	68.95	69.15	69.85	69.30	-	_

SHVS#2: C1 --> C2 --> C3 ~ -10.0 kW / +145.0 kW SHVS#1-4: C1, C2 --> C3 > +100 kW NO SIGINICANT FLUCTUATIONS BETWEEN P11, P12

POWER DEPOSITED IN RESISTIVE MAGNETS (RS#) AND BEAM PIPE (BP#).

Cu	C1(P11)	C1(P12)	C2(P11)	C2(P12)	C3(P11)	C3(P12)
RS#1+2	113.20	113.60	110.85	111.40	498.80	498.80
RS#3	48.45	49.32	46.61	49.11	155.95	135.45
RS#4+5	63.35	63.45	63.65	65.25	157.70	156.80
RS#1-5	225.00	226.37	222.11	225.76	812.15	791.05

RS#1+2: C1, C2 --> C3 > 3.4 TIMES MORE TDP WITHOUT SH1 (+386.0 kW) RS#1-5: ~ 225 kW --> 812 kW (+587 kW) P11, P12 SMALL DIFERENCES FOR C1, C2 AND ~ 20 kW FOR C3

BP	C1(P11)	C1(P12)	C2(P11)	C2(P12)	C3(P11)	C3(P12)
BP#1(W)	439.15	436.90	439.97	434.50	361.10	360.45
BP#2(ST)	245.80	242.05	247.85	242.40	269.50	265.50
BP#3(ST)	9.16	8.87	9.46	8.66	9.07	9.40
BP#1-3	694.11	687.82	697.28	685.56	639.67	635.35

BP#1: C1, C2 --> C3 ~ -80.0 kW BP#2: C1, C2 --> C3 ~ +24.0 kW BP#1-3: C1, C2 --> C3 ~ -54.33 kW P11, P12 IN BP#1-3 DIFFERENCES BETWEEN 5-10 kW.

SUMMARY FOR TOTAL POWER DEPOSITED IN DIFFERENT AREAS.

TOTALS	C1(P11)	C1(P12)	C2(P11)	C2(P12)	C3(P11)	C3(P12)
SC#1-19	0.56	0.50	0.55	0.50	0.53	0.62
SH#1-4	1603.07	1589.06	1248.63	1238.38	813.97	803.25
SHVS#1-4	182.06	189.81	197.41	188.35	290.37	296.55
RS#1-5	225.00	226.37	222.11	225.76	812.15	791.05
BP#1-3	694.11	687.82	697.28	685.56	639.67	635.35
Hg TARG.	413.50	409.00	412.25	407.90	412.45	408.60
Hg POOL	_	_	317.50	333.35	320.80	337.60
HgP.WALLS	7.00	7.67	11.83	13.00	11.93	13.19
Be WIND.	7.78	7.89	7.63	7.40	7.69	7.41
TOTAL	3202.03	3187.27	3185.04	3169.50	3309.56	3293.62

SC#1-19: ~ 0.5 FOR ALL CASES SH#1-4: ~ 1/2 THE POWER WITHOUT SH1 (~ -790.0 kW) RS#1-5: ~ 2.5 TIMES MORE DP WITHOUT SH1 (~ +587.0 kW) BP#1-3: ~ -55.0 kW LESS DP WITHOUT SH1 BeWind: ~ 7.4-7.7 kW

SC#1-11 PEAK VALUES.

PEAK(mW/g)	C1(P11)	C1(P12)	C2(P11)	C2(P12)	C3(P11)	C3(P12)
SC#1	0.025	0.018	0.028	0.027	0.020	0.035
SC#2	0.009	0.010	0.018	0.016	0.015	0.018
SC#3	0.007	0.009	0.012	0.016	0.014	0.020
SC#4	0.011	0.014	0.013	0.012	0.014	0.016
SC#5	0.011	0.012	0.004	0.005	0.007	0.020
SC#6	0.009	0.005	0.006	0.002	0.002	0.002
SC#7	0.005	0.003	0.005	0.014	0.007	0.001
SC#8	0.075	0.035	0.054	0.050	0.035	0.170
SC#9	0.045	0.050	0.070	0.140	0.055	0.040
SC#10	0.060	0.070	0.006	0.070	0.060	0.040
SC#11	0.060	0.050	0.040	0.042	0.060	0.050

PEAK VALUES WITH EXCEPTION OF TWO CASES MUCH LOWER THAN

0.15 mW/g

SC#9 FOR C2(P12) AND SC#8 FOR C3(P12) CASES APPEAR TO HAVE PROBLEM. WE DON'T HAVE THAT PROBLEM FOR P11 POINT. PEAK VALUES SHOW SENSITIVITY ON INJECTION POINT FOR PROTONS BEAM.