

IDS120h GEOMETRY WITH MODIFIED Hg POOL VESSEL

SIMULATIONS FOR 60% W + 40% He SHIELDING (P11/P12 'POINTS') (CONT.)

DETAILED STUDY FOR DP IN SC#8 AND SC#9

Nicholas Souchlas, PBL (12/13/2011)

IDS120hm: (m IS FOR) modified Hg pool vessel IN IDS120h.
1E5 AND 5E5 SIMULATIONS COMPARISON.
DETAIL ANALYSIS OF TDP IN SC#8 AND SC#9.
PROTECTING THE SC's IN THE "STAIRS"
P11/P12 INITIAL PROTON BEAM POSITION SIMULATIONS.

>mars1510/MCNP

>10⁻¹¹ MeV NEUTRON ENERGY CUTOFF


>SHIELDING: 60% W + 40% He (WITH W VESSELS)

>4 MW proton beam, Np = 100,000/500,000 events.

>PROTONS ENERGY E = 8 GeV.


>GAUSSIAN PROFILE: $\sigma_x = \sigma_y = 0.12$ cm.

**IDS120hm GEOMETRY = IDS120h WITH MODIFIED Hg POOL VESSEL
AND SHIFTED Be WINDOW FROM 600 cm (0.6 cm THICK) TO 300 cm (1 cm THICK).**



Aspect Ratio: Y:Z = 1:2.04545

MODIFIED Hg POOL EXTENDS FROM 86 cm TO ~ 300 cm ALONG THE z-AXIS AND UP ~ 50 cm RADIALLY




Aspect Ratio: Y:Z = 1:7.1

SH1-->SH1A

SH2-->SH1B + SH2


1 cm THICK STST WALLS USED FOR THE Hg POOL VESSEL



Aspect Ratio: Y:Z = 1:0.25

1 cm THICK Be WINDOW IS LOCATED AT 300 cm (ORIGINALLY 0.6 cm THICK PLACED AT 600 cm)


**P11 AND P12 INITIAL PROTONS BEAM POSITION POINTS WILL BE USED FOR THE SIMULATIONS.
PROJECTION OF P11 (BLACK) AND P12 (RED) PROTONS TRAJECTORY PLOTS.**



YZ PROJECTION




Aspect Ratio: Y:Z = 1:10.0



XZ PROJECTION

Ratio: X:Z = 1:10.0





XY PROJECTION



Aspect Ratio: X:Y = 1:1.0

P12 PROTONS ENTER THE Hg POOL SOONER AND THEREFORE HAVE A LONGER TRAJECTORY.

IDS120hm WITH Hg IN THE POOL UP TO $y = -20$ cm WITH SH1 (LEFT) AND WITHOUT SH1 (RIGHT)



TABLES NOTATION: C2(P11/P12)A/B = IDS120hm WITH Hg IN THE POOL VESSEL,

SURFACE AT $y = -20$ cm (A = 1E5, B = 5E5 EVENTS)

C3(P11/P12) = IDS120hm WITHOUT SH#1, Hg POOL SURFACE AT $y = -20$ cm

FOR EACH CASE BOTH P11 / P12 INITIAL PROTON BEAM POSITIONS EXAMINED

POWER DEPOSITED IN THE SC COILS

NiSn/NiTi	C2(P11)A	C2(P11)B	C2(P12)A	C2(P12)B
SC#1	0.209	0.200	0.160	0.204
SC#2	0.042	0.041	0.044	0.060
SC#3	0.042	0.053	0.044	0.043
SC#4	0.028	0.032	0.026	0.025
SC#5	0.004	0.005	0.007	0.005
SC#6	0.001	0.002	0.001	0.002
SC#1-6	0.326	0.333	0.282	0.339
SC#7-9	0.060	0.058	0.050	0.062
SC#10-12	0.070	0.066	0.050	0.055
SC#13-15	0.026	0.038	0.044	0.038
SC#16-19	0.063	0.070	0.070	0.064
SC#1-19	0.545	0.565	0.496	0.558

SC1: ~ 0.2 kW SC1-6: ~ 0.33 kW SC#1-19: > 0.5 kW

MOST SIGNIFICANT DIFFERENCES IN SC's TDP OBSERVED FOR P12 POINT.

POWER DEPOSITED IN THE SHIELDING (SH#), SHIELDING VESSELS (SHVS#), AND SH1 W TUBE 2 (SH1T2)

–	C2(P11)A	C2(P11)B	C2(P12)A	C2(P12)B
SH#1A	560.50	558.00	560.50	559.50
SH#1B	340.70	341.50	391.70	389.90
SH#2	244.20	242.55	181.45	184.35
SH#3	24.08	24.11	22.18	22.73
SH#4	79.15	79.35	82.55	81.45
SH#1-4	1248.63	1246.01	1238.38	1237.93

P11, P12 AGREEMENT WITHIN ~ 1-2 kW

–	C2(P11)A	C2(P11)B	C2(P12)A	C2(P12)B
SHVS#1	61.80	57.05	49.74	58.30
SHVS#2	93.55	93.10	92.90	94.20
SHVS#3	0.83	0.88	0.77	0.85
SHVS#4	41.23	41.76	44.94	44.11
SHVS#1-4	197.41	192.79	188.35	197.46
SH1T2(W)	69.85	69.50	69.30	69.95

SHVS#1: MOST SIGNIFICANT DIFFERENCE, ESPECIALLY FOR P12

POWER DEPOSITED IN RESISTIVE MAGNETS (RS#) AND BEAM PIPE (BP#).

Cu	C2(P11)A	C2(P11)B	C2(P12)A	C2(P12)B
RS#1+2	110.85	110.50	111.40	111.05
RS#3	46.61	47.71	49.11	48.81
RS#4+5	63.65	63.35	65.25	64.45
RS#1-5	222.11	221.56	225.76	224.31

VERY SMALL DIFFERENCES FOR BOTH P11, P12

BP	C2(P11)A	C2(P11)B	C2(P12)A	C2(P12)B
BP#1(W)	439.97	438.25	434.50	437.15
BP#2(ST)	247.85	247.00	242.40	246.80
BP#3(ST)	9.46	9.51	8.66	8.75
BP#1-3	697.28	694.76	685.56	692.70

MOST SIGNIFICANT DIFFERENCES OBSERVED FOR BP#1 AND BP#2 FOR P12

SUMMARY FOR TOTAL POWER DEPOSITED IN DIFFERENT AREAS AND ENERGY FLOW.

TOTALS	C2(P11)A	C2(P11)B	C2(P12)A	C2(P12)B
SC#1-19	0.55	0.57	0.50	0.56
SH#1-4	1248.63	1246.01	1238.38	1237.93
SHVS#1-4	197.41	192.79	188.35	197.46
RS#1-5	222.11	221.56	225.76	224.31
BP#1-3	697.28	694.76	685.56	692.70
Hg TARG.	412.25	412.00	407.90	408.80
Hg POOL	317.50	323.40	333.35	327.70
HgP.WALLS	11.83	11.79	13.00	12.87
Be WIND.	7.63	7.53	7.40	7.39
TOTAL	3185.04	3179.91	3169.50	3179.67

TDP FLOW (kW)	C2(P11)A	C2(P11)B	C2(P12)A	C2(P12)B
R=200 cm	156.68	156.09	145.23	151.72
z=-250 cm	177.55	178.90	176.50	173.39
z=1900 cm	404.06	406.60	396.34	400.55
TOTAL FLOW	738.29	741.59	718.07	725.66
TOTAL	3923.33	3921.50	3887.57	3905.33
(TOTAL-4 MW)	-76.68	-78.50	-114.43	-94.67

SC#1-19: ~ SAME FOR ALL CASES

SH#1-4: ~ ABOUT SAME FOR BOTH P11, P12

RS#1-5: ~ ABOUT SAME FOR BOTH P11, P12

BP#1-3: ~ -2.52 kW (P11) / ~ -7.14 kW (P12)

BeWind: ~ 7.4-7.6 kW


LARGER DIFFERENCES IN P12 POINT AND ENERGY 'GAPS' MORE THAN THOSE IN P11 CASES.

SC#1-11 PEAK VALUES.

PEAK(mW/g)	C2(P11)A	C2(P11)B	C2(P12)A	C2(P12)B
SC#1	0.028	0.018	0.027	0.016
SC#2	0.018	0.090	0.016	0.014
SC#3	0.012	0.016	0.016	0.008
SC#4	0.013	0.020	0.012	0.012
SC#5	0.004	0.003	0.005	0.003
SC#6	0.006	0.003	0.002	0.001
SC#7	0.005	0.003	0.014	0.001
SC#8	0.054	0.040	0.050	0.055
SC#9	0.070	0.060	0.140	0.060
SC#10	0.006	0.055	0.070	0.045
SC#11	0.040	0.048	0.042	0.035


SC#9: C2(P12) CASE APPEAR TO BE ESPECIALLY SENSITIVE TO STATISTICAL UNCERTAINTIES.

**SC#9 ANGULAR SEGMENTATION FOR TDP DETAILED STUDIES:
8 SECTIONS EXTENDING OVER THE WHOLE LENGTH OF THE COIL.
(MANY THANKS TO SERGEI STRIGANOV)**



PLOT AND DATA TABLE FOR DP IN 8 SECTIONS OF SC#8 OR SC#9 FOR C2 OR C3 CASE.

TDP IN SC#8 FOR C3 AND SC#9 FOR C2 CASES (P11/P12 POINTS) IN Watts



DATA TABLE FOR DP(W) IN 8 SECTIONS



SECTION	C2(P11)	C2(P12)	C3(P11)	C3(P12)
#1	2.78	2.20	3.20	1.80
#2	0.84	1.50	2.90	3.60
#3	2.40	2.70	2.30	1.30
#4	2.30	0.69	0.80	1.20
#5	3.60	1.50	2.50	3.00
#6	5.90	3.30	5.40	0.90
#7	3.30	2.80	6.20	1.40
#8	3.40	1.80	6.70	4.30
TOTAL	24.52	16.49	30.00	17.50
SC#7+8	43.00	24.00	—	—
SC#7+9	—	—	25.00	28.00
SC#7-9(N)	67.52	40.49	55.00	45.50
SC#7-9(B)	60.00	50.00	47.00	49.00

N = DP IN SC#7-9 FROM SEGMENTATION STUDIES
B = DP IN SC#7-9 FROM ORIGINAL SIMULATION

C2(P11/P12): S#6 RECEIVES MOST OF DP (5.9/3.3 W)

C3(P11/P12): S#8 RECEIVES MOST OF DP (6.7/4.3 W)

DEALING WITH THE PROBLEM OF SH#8 AND SC#9 PEAK VALUES



REINFORCING SH#2 AND SH#4 RIGHT SIDE FLANGES (10 cm --> 14 cm THICKNESS).

BEFORE: TDP SC#7-9 (0.049 kW), PEAK SC#7/8/9 (0.001/0.170/0.040 mW/g)
AFTER: TDP SC#7-9 (0.005 kW), PEAK SC#7/8/9 (0.001/0.027/0.100 mW/g)
TDP SHVS2RFL/SHVS4RFL (0.773/0.010 kW)