

Hg Delivery System Nozzle Discussion

Van Graves

25 Oct 2005

MERIT Mtg at MIT Oct 17-19



- **During Hg delivery system design review, discussion initiated concerning nozzle changeouts at MIT**
 - **Current design requires decoupling of delivery system from magnet bore to access nozzle**
 - **Operationally preferable to have access to nozzle while inserted in magnet bore**





Requirements & Desirables for Up-beam Access



- **Change direction of access of mechanical fasteners**
- **Addition of a flange interface on the up-beam end of the system**
- **Removable secondary containment flange**
- **Accommodate plenum or non-plenum nozzle configurations**

McDonald Flange

- **Kirk provided sketch of intermediate flange concept designed to accept plenum & non-plenum configurations**
 - Incorporates o-ring seals
- **Conceptual models developed as discussion tool**
 - Presentation based on subjective information




OAK RIDGE NATIONAL LABORATORY
U. S. DEPARTMENT OF ENERGY

UT-BATTELLE


Conceptual Configurations

- Attaching plenum from up-beam end requires smaller diameter plenum
- Rigid supply tubing must bend towards center to accommodate flange bolt circle
- Non-plenum tubing requires Hg flow to bend away from center (adds 4 bends before 180-deg turn)




Removable Plenum Concept

- Adding exterior bolts reduces plenum ID
- Beam tube positioning will be problem
- Plenum wall thicknesses may not be representative



Secondary Flange

- Radial screws provide most clearance for removal of nozzle
- Secondary sleeve not thick enough for flat-head screws
 - Adding thickness reduces clearance for removing nozzle
- Requires fairly precise sleeve/flange fabrication to achieve proper sealing



My Opinions



- **Intermediate flange bolt spacing probably not realistic**
 - High pressure will require tight spacing
 - Preventing o-ring groove overlap may prove difficult
- **In-line access to all bolts not possible, especially with non-plenum configurations**
 - Magnet bore sleeve extension makes problem worse
 - Other magnet connections may not allow direct hands-on access anyway
- **Radial attachment of secondary endplate difficult without reducing ID of secondary bore**
- **Mechanics of removable plenum creates severe space limitations**
 - Wall thicknesses of plenum may increase to accommodate Hg pressure
 - Inlet effects into nozzle may be affected
- **We are increasing potential leak paths & possible failure modes**
 - My guesstimate for nozzle changeout in current configuration is 1-2 days
- **Selection of plenum or non-plenum should be made ASAP (with Princeton water tests if possible), not try to carry both approaches through fabrication**