

## MERIT Hg System Final Design Review

## **Hg Target System Design**

V.B. Graves P.T. Spampinato T.A. Gabriel

MERIT Collaboration Meeting MIT Plasma Science & Fusion Center Oct 5, 2005

> OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY

## **Outline - Component Details**



- Syringe
- Primary containment
- Secondary containment
- Baseplates

OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



# **Hg Delivery System**



- Capacity 23liters Hg (~760 lbs)
- Provides 1cm dia, 20m/s jet for up to 12 sec
- Secondary containment size 960mm x 1475mm x 960mm
- Estimated weight 2T with Hg







# **Hg Syringe System**







OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



### **Hg Syringe System**



- Hg flow rate 1.6liter/s (24.9gpm)
- Piston velocity 3.0cm/s (1.2in/sec)
- Hg cylinder force 525kN (118kip)





## **Fathom Flow Simulation**



- System diagram for Hg flow
- Results indicate maximum pressure requirement of ~780 psi (50 bar) for baseline plenum/nozzle configuration
- Design system for max pressure of 1000 psig (70 bar)





## **Fathom Details**

Die . Outenut Table



Pipe (	Jutput Table													
		Pipe			Flow					P Stag.	dP Stag.		P Static	dP Static
		Nominal	Vol. Flow	Length	Area	Velocity	Reynolds		P Stag.	Out	Total	P Static	Out	Total
Pipe	Name	Size	(gal/min)	(inches)	(inches2)	(feet/sec)	No.	fL/D+K	In (psig)	(psig)	(psid)	In (psig)	(psig)	(psid)
	1 Hg Cylinde	10 inch	24.9	15	78.854	0.101	6.86E+04	0.0296	784	784	2.77E-05	783.9	784	2.77E-05
	2 Cylinder D	1 inch	24.9	1.5	0.864	9.24	6.56E+05	0.0256	780	780	0.199779	772.2	772	0.199779
	3 Cylinder D	1 inch	24.9	0.8	0.864	9.24	6.56E+05	0.0136	777	776	0.302768	769	769	0.302768
	4 Hg Manifol	1 inch	24.9	16.1	0.864	9.24	6.56E+05	0.2745	774	764	9.772281	765.9	756	9.772281
	5 Hose Inlet	1 inch	24.9	2.1	0.864	9.24	6.56E+05	0.0358	761	760	0.279691	752.8	752	0.279691
	6 Flex Metal	1 inch	24.9	10.5	0.945	8.449	6.27E+05	0.17	760	759	1.110492	753.7	753	1.110492
	7 Hg Supply	1 inch	24.9	1.86	0.594	13.433	7.91E+05	0.0284	755	755	0.469346	738.7	738	0.469346
	8 Hg Supply	1 inch	24.9	6.7	0.594	13.433	7.91E+05	0.1024	752	750	1.690654	735.3	734	1.690654
	9 Hg Supply	1 inch	24.9	44	0.594	13.433	7.91E+05	0.6726	747	736	11.1028	730.8	720	11.1028
	10 Plenum	5 inch	24.9	3	20.006	0.399	1.36E+05	0.0105	721	721	0.000153	720.6	721	0.000153
	11 Nozzle	1/2 inch	24.9	4	0.108	74.271	1.86E+06	0.1491	469	394	75.21312	-35.3	-110	75.21312
All Ju	nction Table													
			Elevation				P Stag.	dP Stag.		P Static	dP Static			
		Junction	Inlet	Loss	dH	P Stag.	Out	Total	P Static	Out	Total	T Inlet	1	
Jct	Name	Туре	(inches)	Factor (K)	(inches)	In (psig)	(psig)	(psid)	In (psig)	(psig)	(psid)	(deg. F)		
	1 Syringe Pi	Assigned	0	0	0	784	784	. 0	784	783.9	0	68		
	2 Area Chan	Area Chan	0	4,128.12	7.895	784	780	3.8729	784	772.2	11.682	68.2		
	3 Bend 1	Bend	0	0.33841	5.388	780	777	3.011	772	769	3.011	68.2		
	4 Bend 2	Bend	1.15	0.27347	4.354	776	774	2.7736	769	765.9	2.774	68.2		
	5 Bend 3	Bend	18	0.33841	5.388	764	761	3.3789	756	752.8	3.379	68.3	_	
	6 Pipe to Fle	Area Chan	19.5	0.00733	0.117	760	760	0.0572	752	753.7	-1.223	68.3		
	7 Flex to Tul	Area Chan	19.5	0.60087	7.999	759	755	3.924	753	738.7	13.901	68.3		
	8 Tubing Be	Bend	19.5	0.17406	5.857	755	752	2.8734	738	735.3	2.873	68.3		
	9 Tubing Be	Bend	19.5	0.17406	5.857	750	747	2.8734	734	730.8	2.873	68.3		
100	10 Plenum Inl	Area Chan	19.5	0.94145	31.682	736	721	15.5414	720	720.6	-0.952	68.3		
	11 Nozzle Inle	Area Chan	19.5	17,240.17	512.271	721	469	251.2909	721	-35.3	755.894	68.3		
	12 Spray	Spray Disc	19.5	0.78106	802.957	394	0	393.8837	-111	-504.6	393.884	75		

#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



# **Other Fathom Simulations**



- 1/2" tubing bend
  - Cylinder pressure 1200 psi (83 bar)
- No-bend short 1/2" tube
   Cylinder pressure 710 psi (48 bar)
- 1" tubing bend
  - Cylinder pressure 780 psi (54 bar)
- All 1/2" tubing from end of flex metal hose, no plenum
  - Cylinder pressure 1910 psi (130 bar)
- Any non-plenum design should minimize number of bends & length of nozzle tubing
- Don't let syringe pump limit nozzle configuration - recommend changing system design pressure to 1500 psi (103 bar) to match Hg cylinder rating

OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY







## **Non-Plenum Nozzles**

- Room is available to eliminate plenum, keep tubing under beam
- Flow streamlines become more of an issue
  - Desire to move bend further from nozzle







#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



### **Syringe Procurement**



- Complete system design based on specified requirements
- Piston pump (inside secondary containment)
  - One 10-inch Hg Pump Cylinder
  - Two 6-inch Drive Cylinders (one with integrated position sensor)
  - Tie beam
  - Baseplate
  - Hydraulic hoses inside secondary for operating Drive Cylinders
- Hydraulic pump (outside secondary containment)
  - Pump, motor, reservoir
  - Proportional, directional control valve
  - Hydraulic hoses between pump & secondary containment
  - Motor controller
  - Variable voltage transformer for U.S. and European operation
- Hydraulic fluid (drum)
- Integration of system components
- System testing with water









## **Syringe Procurement Status**



### RFQ sent to 5 vendors, 4 submitted quotes

- Requested prices for std cylinders & SS cylinders
- Low bid: \$60K (std), \$68K (SS)
- Subcontract awarded to Airline Hydraulics (Edison, NJ)
- Chose SS cylinder option
- Kickoff meeting being scheduled for next week

 Vendor required to host a syringe design review 30 days after contract award, prior to ordering materials

OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



# **Syringe Hydraulic Schematic**





Bill of Materials									
Find No.	Name	Description	Qty.						
1	pump and motor	TEFC motor, pump, mounted vibration absorbing pads	1						
2	relief valve	set for 3300 PSI	1						
3	filter	filter with electrical filter dirty switch and bypass valve	1						
4	level switch	reservoir low level cutoff switch	1						
5	hose	hose length 65 ft, quick connections both ends	2						
6	proportional valve	Bosh 4 WREE or equivalent	1						
7	ball valve	reservoir drain valve with TBD end fitting	1						
8	hydraulic cylinder	hydraulic cylinder, 15" stroke	2						
9	hydraulic cylinder	mercury syringe cylinder, bore 10°, stroke 15°, 4 ports as noted	1						
10	tie-beam	beam providing mechanical connection between cylinders	1						
11	pressure sensor	electronic pressure sensor with attachable indicator display, 0-4000 psi, signal 4-20ma	1						
12	pressure sensor	electronic pressure sensor with attachable indicator display, 0-500 psi, signal 4-20ma	1						
13	position sensor	linear potentiometer, Celesco CLWG or equivalent	2						
14	ball valve	cylinder drain valve with TBD end fitting	1						

August 24, 2005

#### **OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY**



# **Primary Containment**

- Hg supply flow path
  - 1-inch Sch 40 pipe
  - 1-inch flex metal hose w/sanitary fittings
  - 1-inch, 0.065-wall rigid tubing
  - 5-inch diameter plenum
  - 12mm-dia, 1mm-wall rigid tubing



#### • Hg jet return path

- 1/4-inch plate weldment chamber
- 6-inch to 2-1/2-inch eccentric reducer
- 2-1/2-inch flex metal hose w/sanitary fittings
- Sump tank

#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Normal Syringe Operations**



- Slowly extend cylinder to fill Hg cylinder from sump
- Slowly retract cylinder to starting position & prefill Hg supply piping
- Some time after trigger is received, ramp cylinder to full speed
  - Need engineering solution to prevent possibility of sudden cylinder start – will discuss with syringe vendor
- Steady-state jet for 1sec
- Ramp cylinder to zero velocity
  - Sudden stop can cause flow separation & Hg hammer





## **Sump Tank**

- Fabrication: 1/4" plate SS304L/316L
- Ports for Hg fill & extraction, Hg level sensor, syringe vents, breather checkvalves, supply line relief

on 00 UT-BATTELLE

OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY

## **Sump Tank Analysis**



800-lb Hg load on tank bottom
Min FOS > 9

<complex-block>

OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



MERIT Collab. Mtg Oct 17-29, 2005

sump tank hit-hg weight :: Design Check Criterion : Max von Mises Stress

Deformation Scale 1:0

Factor of safety distribution: Min FOS = 9.2

# Manifold



Model name: hg manifold hit Study name: COSMOSXpressStudy Plot type: Static nodal stress Plot1 Deformation scale: 4456.01

 Designed for socket weld fabrication, SS304L/316L

#### Channels

- Flow 1" pipe
- Hg cylinder vent 1/2" tube
- Sump drain 3/4" pipe
- Pressure transducer 1/2" tube
- Relief valve 3/4" tube

#### FEA results

- FOS = 4.8 for 1000 psi
- Will be redesigned for 1500 psi

#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Hg Plenum**



 Fabrication incorporates nozzle, beam window, and Hg supply tubing

Replaceable module





#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY





## **Primary Containment Pressure Ratings**



Pressure Ratings Table

OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



### **Primary Containment Beam** Windows



- Single layer Ti6Al4V, 1mm thick
- Hg deflector acts as beam window, made from same material
- Horizontal beam kick
  - 6mm @ primary window
  - 18mm @ secondary window
- Downstream window sized to accommodate horizontal beam kick and small changes in magnet tilt



OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Hg Deflector**



- Simplifying analysis indicates imparted force on plate of 425N (95lb)
- Using Ti6Al4V thickness of 1mm gives a safety factor < 1</li>
- Recommend deflector thickness of 2mm
   FS = 3.5



# **Accommodating Tilt Changes**



- Hg delivery system can accommodate some amount of decreasing tilt angle and keep beam in windows
  - 30mrad upstream
  - 33mrad downstream



#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY

dY: 28.84mm



### **Beam Window Fabrication Issues**



- Do not have definitive answer to question of weldability between Ti6AI4V and SS304L/316L
- If reliable process is found, it likely will require some development by fabricator to establish welding parameters
  - Material samples and added cost
- Can windows be SS316L/304L?



## **Secondary Containment**



- SS304L/316L 1/2" bottom plate, 1/4" front, sheet metal sides & back (7ga, 0.179")
   May add stiffeners to sides & back
- Flexible sleeve (non-metallic, combustibility issue)
- SS304L/316L cylindrical sleeve (13ga, 0.089")
- Passive filtration
  - Filtered inlet and outlet, both will be have shutoff gates



#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## Secondary Containment Double Beam Windows



- Similar in construction to Hg plenum
- SS pipe with Ti6Al4V caps
  - All Ti if necessary, but attachment to secondary containment still an issue
- Flexible tubing back to hydraulic system
- Pressurize and monitor to detect failure
  - Can also vacuum monitor, but pump and larger tubing required
  - Will test at ORNL, determine final method



OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## Secondary Containment Access Ports



- Optical diagnostics
- Instrumentation
- Hydraulics
- Hg drain & fill (without opening secondary)
- Hg extraction (in event of major leak in primary containment)



OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Secondary Containment Monitoring and Filtering**



- Two Hg vapor monitors for secondary volume
- Passive filtration with shutoff, can connect to active filtration system
  - Will have single cartridge rather than respirators
- Third vapor monitor for passive filter exhaust and/or tunnel monitoring
- Investigating whether monitors can be moved away from experiment

OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



### **Baseplates**



 Purpose – provide mobility, alignment, and structural support for experiment components
 – Experiment requires magnet tilt of 66mrad (3.8°)

### Two baseplates

- Target transporter
- Common baseplate



## **Target Transporter**



- Transports Hg system inside tunnel using Hilman rollers

   O/A length 62" (1.6m)
- Rails for Hg system cart wheels
- Jack bolts prevent rolling
- Swivel hoist rings for lifting & cart tiedown
- Material: AL6061-T6





OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **MERIT Side View**





#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Common Baseplate**



- Shares design with transporter baseplate
   O/A length 124" (3.15m)
- Rollers used to grossly align solenoid to beam
- Provides lateral movement of solenoid for alignment to beam once rollers removed



OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## Design Constraints & Requirements



- Total supported weight
  - Magnet: 9000 lbs
  - Hg System with 23liter Hg: 4000 lbs
  - Baseplate: 1000 lbs
  - Movement requires lateral force of 700 lbs (μ<sub>s</sub> = 0.05 per Hilman)
- Maximum width of 1.3m (51") to meet CERN facility constraints
- Fabrication material to be non-magnetic (chose AL 6061-T6)
- Must have lifting & leveling provisions
- Currently not anchored to floor is there a need?

OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Common Baseplate Structure**

- 4-inch AL channel frame, I-beam internal supports
- Hilman roller support plates
- Welded leveling jack gusset plates
- Side-load swivel hoist rings for lifting
- Removable jack stand gussets



#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY





## **Magnet Lateral Alignment**



- Gross adjustment provided by Hilman rollers
- Low-friction surface plate sits between magnet support plate and baseplate
- Weld studs with nuts hold final position
- Jackbolts provide lateral moving force
- Lateral adjustment range ±25mm



OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Common Baseplate Structural Analysis – 3 Rollers**



### Condition: loaded baseplate carried by 3 Hilman rollers



#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Common Baseplate Structural Analysis – 4 Lift Jacks**



#### Condition: loaded baseplate supported by 4 hydraulic jacks



#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Common Baseplate Structural Analysis - 4 Leveling Jacks**



### Condition: loaded baseplate supported by 4 leveling jacks

### • Min FOS=1.8 in localized areas



#### OAK RIDGE NATIONAL LABORATORY U. S. DEPARTMENT OF ENERGY



## **Some Final Design Details**



 Some dimensions of Hg delivery system can't be finalized until syringe design is complete

• Will need magnet as-built height on its base





# **Remaining Design Work**



- Finalize procured component details for drawings
- Drawing check
- Sensor / instrumentation wiring diagram
- Generate fabrication vendor list
- Write procurement specification



## **Design Issues**



- Nozzle configuration plenum vs non-plenum
- Nozzle details length, exit features
- Final dimensions for syringe system, magnet height

